



## Method Statement

<b>Date:</b> 14/03/16	<b>Review:</b> 14/03/18	<b>MS No:</b> MD115
<b>Task:</b> Recharging of Portable Fire Extinguishers		
<b>Area of Works:</b> On site		
<b>Resources</b>		
<b>Supervision:</b> None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices.		
<b>Operatives:</b> Senior service engineer		
<b>Equipment:</b> Competent qualified personnel to QAS3169. Low voltage battery operated tools to be used for fixing extinguishers and nitrogen for pressurising extinguishers. Operatives carry a comprehensive first aid kit and are provided with all the necessary PPE required.		
<b>Substances:</b> Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products.		
<b>Training:</b> Appropriate trade training		
<b>Identified hazards (refer to relevant RAMS and COSHH data)</b> MD114 MD135		
<b>Method of Works:</b> All portable fire extinguishers are recharged to manufacturers recommendations. A safe well-ventilated site will be sought to undergo all charging operations.		
Approved by _____		