



Method Statement

Date: 14/03/16	Review: 14/03/18	MS No: MD121
Task: Working at height		
Area of Works: On site		
Resources		
Supervision: None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices.		
Operatives: Senior service engineer (authorised and trained to work at height)		
Equipment: Mobile elevating work platforms & Tower Scaffold. Operatives carry a comprehensive first aid kit and are provided with all the necessary PPE required.		
Substances: Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products.		
Training: Appropriate trade training		
Identified hazards (refer to relevant RAMS and COSHH data) MD120 MD122 MD125		
Method of Works: No work is to be carried out on any roof without a signed permit to work from O Heap and son. All equipment used to work at height must be inspected for safety prior to use. Faulty access equipment must be reported and replaced. For tasks of 30 minutes or less in duration serviceable stepladders and ladders can be used in line with risk assessment. Where working at height poses a hazard to others from machinery or falling objects the area shall be cordoned off.		
Approved by _____		
Chase Fire Protection Ltd		