



Method Statement

Date: 14/03/16	Review: 14/03/18	MS No: MD129
Task: Fire Suppression System Maintenance & Servicing		
Area of Works: On site		
Resources		
Supervision: None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices.		
Operatives: Senior service engineer		
Equipment: Low voltage battery operated tools to be used Operatives carry a comprehensive first aid kit and are provided with all the necessary PPE required.		
Substances: Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products.		
Training: Service engineers trained in accordance with BS5839 Part 1:2002, BS7273 PT 1:2006 & PT 2 1992, EN15004, BS5306		
Identified hazards (refer to relevant RAMS and COSHH data) MD128		
Method of Works: Engineer to report to the site supervisor and sign the site register obtaining the relevant permit to work. Engineer to carry out any isolation or disablement necessary. Return system to normal condition after servicing has been carried out.		
Approved by _____		
Chase Fire Protection Ltd		