



Method Statement

Date: 14/03/16	Review: 14/03/18	MS No: MD132
Task: Use of Fire Training (no rig)		
Area of Works: On site		
Resources		
Supervision: None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices.		
Operatives: Senior service engineer (authorised and trained to work on training trailer)		
Equipment: Training trailer Source of ignition		
Substances: Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products.		
Training: Appropriate trade training		
Identified hazards (refer to relevant RAMS and COSHH data) MD131		
Method of Works: The operator must stand at a distance of not less than 3 metres from the trailer when carrying out demonstrations. Students must stand at a distance of not less than 3 metres from the trailer during demonstrations. Warn students prior to the use of the pyrotechnic flash simulator. Permit those with heart conditions or a nervous disposition to leave the area prior to the demonstration. Regularly inspect the condition of hoses for signs of damage or deterioration. When unattended, gas cylinders to be turned off at the manual control valve.		
Approved by _____ Chase Fire Protection Ltd		