



Activity: Fire Hydrant Inspection

Assessors Name:	Chris Ogden	5. Extreme	5 (LOW)	10 (MED)	15 (MED)	20 (HIGH)	25 (HIGH)
Assessors Signature:	Chris Ogden	4. Major	4 (LOW)	8 (MED)	12 (MED)	16 (MED)	20 (HIGH)
Assessment Date:	14/03/16	3. Minor	3 (LOW)	6 (MED)	9 (MED)	12 (MED)	15 (MED)
Contract Title:	Various clients premises throughout the UK	2. Limited	2 (LOW)	4 (LOW)	6 (MED)	8 (MED)	10 (MED)
EFFECTED PERSONS:		1. Trivial	1 (LOW)	2 (LOW)	3 (LOW)	4 (LOW)	5 (LOW)
Visitors			1. Unlikely	2. Rarely	3. Occasional	4. Frequent	5. Inevitable
Employees	<input checked="" type="checkbox"/>		RATING		REVIEW PERIOD: 2 Years		
Contractors			HIGH RISK		Intolerable - Do not start work		
Public	<input checked="" type="checkbox"/>		MED RISK		Tolerable - Reduce ALARP. Review annually/change.		
Others (specify)			LOW RISK		Tolerable - Monitor. Review annually/change.		

No.	Hazard/Aspect Hazardous Event	H&S Consequence Environmental Impact	Pre-control			Control Measures to be Employed	Final Risk		
			Rating				Rating		
			LxS = Risk			LxS = Risk			
1	Accidental contact with pedestrian and vehicular traffic.	Major injury, death, property damage.	3	5	15	Suitable temporary barriers and signage to be used to protect the works area. Hi visibility jacket/vest to be worn.	1	5	5
2	Manual handling - removal/lifting of hydrant cover.	Sprains, strains	3	3	9	Engineers to be trained in good kinetic techniques. Lifting keys and lever bar to be used. Wherever practicable the cover should be slid and not lifted.	1	3	3

