

## Method Statement

<b>Date:</b> 01/01/17	<b>Review:</b> 01/01/19	<b>MS No:</b> MD075
<b>Task:</b> Fixing of portable fire extinguishers and hose reels		
<b>Area of Works:</b> On site		
<b>Resources</b>		
<b>Supervision:</b> None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices.		
<b>Operatives:</b> Service engineers		
<b>Equipment:</b> Hand tools i.e. screwdrivers and low voltage, battery operated tools only to be used by our engineer whom are fully trained in equipment use. Operatives carry a comprehensive first aid kit and are provided with all the necessary PPE required.		
<b>Substances:</b> Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products.		
<b>Training:</b> Appropriate trade training		
<b>Identified hazards (refer to relevant RAMS and COSHH data)</b> MD074		
<b>Method of Works:</b> Engineers are trained to fix portable fire extinguishers to BS 5306 and hose reels to BS 3169. Our engineers are trained to service the said fire equipment at the fire equipment's point of origin. Where this is not possible a safe site will be sought to carry out this task.		
<p>Approved by _____</p> <p>O Heap and Son (Derby) Limited</p>		