



Activity: Fire Safety Training (no rig)

Assessors Name:	Chris Ogden	5. Extreme	5 (LOW)	10 (MED)	15 (MED)	20 (HIGH)	25 (HIGH)
Assessors Signature:	Chris Ogden	4. Major	4 (LOW)	8 (MED)	12 (MED)	16 (MED)	20 (HIGH)
Assessment Date:	01/01/17	3. Minor	3 (LOW)	6 (MED)	9 (MED)	12 (MED)	15 (MED)
Contract Title:	Various clients premises throughout the UK	2. Limited	2 (LOW)	4 (LOW)	6 (MED)	8 (MED)	10 (MED)
EFFECTED PERSONS:		1. Trivial	1 (LOW)	2 (LOW)	3 (LOW)	4 (LOW)	5 (LOW)
Visitors			1. Unlikely	2. Rarely	3. Occasional	4. Frequent	5. Inevitable
Others (specify)	X		RATING		REVIEW PERIOD: 2 Years		
Employees	X	Public	HIGH RISK		Intolerable - Do not start work		
Contractors			MED RISK		Tolerable - Reduce ALARP. Review annually/change.		
			LOW RISK		Tolerable - Monitor. Review annually/change.		

No.	Hazard/Aspect Hazardous Event	H&S Consequence Environmental Impact	Pre-control		Control Measures to be Employed	Final Risk			
			Rating	LxS = Risk		Rating	LxS = Risk		
1	Environmental issues	Site-specific hazards Adverse weather	3	3	9	On arrival at clients site report to reception and undergo any relevant site inductions. Observe all site safety rules. Wear high viz vest when setting up and conducting practical training. Wear appropriate wet weather gear. Suspend training where weather becomes a safety issue (e.g. high winds)	1	3	3
2	Discharging of fire extinguishers	Release of pressurised substances (extinguishing media)	3	2	6	Demonstrations and supervision of trainee use of fire extinguishers by trained and competent trainer. Extinguisher media to be recycled/disposed of according to company procedure. Some of the extinguisher media may, in certain circumstances harm health. The trainer must refer to the appropriate COSHH assessment and strictly follow the controls suggested. Safety glasses to be worn whilst discharging any extinguisher.	2	2	4



O Heap & Son (Derby) Ltd



Chase Fire



Key Fire



Kent Fire

3	Use of live fire during practical session	Burns/smoke inhalation Spread of fire	3	5	15	The operator/trainees must stand at a distance of not less than 3 metres from the tray when carrying out demonstrations/practical training. Demonstrations to be conducted by a competent trainer only. Trainees to be supervised at all times. Equipment to be positioned on level, open ground. Maintain a safe distance of at least 4.5 metres from any building, vehicles or any type of combustible material.	1	5	5
			L	S	R				L S R