

## Method Statement

<b>Date:</b> 01/01/17	<b>Review:</b> 01/01/19	<b>MS No:</b> MD091
<b>Task:</b> Use of Fire Training (no rig)		
<b>Area of Works:</b> On site		
<b>Resources</b>		
<b>Supervision:</b> None required, service engineers trained to work unaccompanied and adhere to any on site local safety practices.		
<b>Operatives:</b> Senior service engineer (authorised and trained to work on training trailer)		
<b>Equipment:</b> Training trailer Source of ignition		
<b>Substances:</b> Assessments will be prepared and available on site and operatives have been fully briefed on the safe use of products.		
<b>Training:</b> Appropriate trade training		
<b>Identified hazards (refer to relevant RAMS and COSHH data)</b> MD090		
<p><b>Method of Works:</b></p> <p>The operator must stand at a distance of not less than 3 metres from the trailer when carrying out demonstrations.</p> <p>Students must stand at a distance of not less than 3 metres from the trailer during demonstrations.</p> <p>Warn students prior to the use of the pyrotechnic flash simulator. Permit those with heart conditions or a nervous disposition to leave the area prior to the demonstration.</p> <p>Regularly inspect the condition of hoses for signs of damage or deterioration.</p> <p>When unattended, gas cylinders to be turned off at the manual control valve.</p>		
<p>Approved by _____</p> <p>O Heap and Son (Derby) Limited</p>		